

DeepOPF-V: Solving AC-OPF Problems Efficiently

Wanjun Huang, Xiang Pan, *Student Member, IEEE*, Minghua Chen, *Senior Member, IEEE*, and Steven H. Low, *Fellow, IEEE*

Abstract—AC optimal power flow (AC-OPF) problems need to be solved more frequently in the future to maintain stable and economic power system operation. To tackle this challenge, a deep neural network-based voltage-constrained approach (DeepOPF-V) is proposed to solve AC-OPF problems with high computational efficiency. Its unique design predicts voltages of all buses and then uses them to reconstruct the remaining variables without solving non-linear AC power flow equations. A fast post-processing process is also developed to enforce the box constraints. The effectiveness of DeepOPF-V is validated by simulations on IEEE 118/300-bus systems and a 2000-bus test system. Compared with existing studies, DeepOPF-V achieves decent computation speedup up to four orders of magnitude and comparable performance in optimality gap, while preserving feasibility of the solution.

Index Terms—AC optimal power flow, deep neural network, voltage prediction.

I. INTRODUCTION

The AC optimal power flow (AC-OPF) problem is a fundamental yet challenging problem in power system operation. With increasing uncertainties brought by intermittent renewables and highly stochastic loads, the AC-OPF problem needs to be solved more frequently to maintain stable and economic power system operation. Therefore, it is of great significance to solve AC-OPF problems with high computational efficiency, especially for large-scale systems.

Leveraging the powerful learning ability of deep neural networks (DNNs), various DNN-based approaches have been proposed to solve AC-OPF problems more efficiently, which can be classified into two main categories: hybrid approach and stand-alone approach. The hybrid approach aims to speed up conventional physics-based solvers (e.g., Matpower Interior Point Solver (MIPS)) by providing warm-start points to accelerate convergence [1] or predicting active [2] or inactive [3] constraints to reduce the problem size. Since it still needs to solve the original or truncated OPF problem iteratively, all operational constraints are considered, but the speedup is limited, i.e., less than one order of magnitude in most studies.

The stand-alone approach predicts the solution of AC-OPF problem directly without solving the optimization problem. Hence, it has a much greater speedup than the hybrid approach. Following the predict-and-reconstruct framework and the handy technique of ensuring box constraints for DC-OPF

[4], [5], several DNN-based approaches are developed for AC-OPF [6]–[8]. These approaches need to solve non-linear power flow equations in their designs, which limits the speedup performance considerably. Different from the above strategies, reference [9] combines DNNs and Lagrangian duality to predict all variables, which reported greater computation speedup. Nevertheless, the critical AC power flow equality constraints may not be satisfied.

In this paper, we propose DeepOPF-V as a DNN-based voltage-constrained approach to solve AC-OPF problems with high efficiency. Our contribution is threefold. First, as presented in Sec. II-B, distinct from previous studies that learn the mapping between loads and generations or all solution variables, DeepOPF-V learns the mapping between loads and voltages of all buses and directly reconstructs the remaining solution variables via simple scalar computation, which guarantees the power flow equality constraints and is expected to achieve decent speedup¹. Second, a fast post-processing process is developed to adjust the predicted voltages in Sec. II-C, which helps to preserve the box constraints and improves the feasibility of the solution. Finally, we carry out simulations using IEEE 118/300-bus systems and a 2000-bus test system in Sec. III. The empirical performance verifies the effectiveness of our design and shows that compared with existing works, DeepOPF-V achieves decent computation speedup up to four orders of magnitude and comparable performance in optimality gap, while preserving feasibility of the solution.

II. MODEL AND METHODOLOGY

A. The AC Optimal Power Flow Problem

The standard AC-OPF problem can be formulated as

$$\min \sum_{i \in \mathcal{N}_G} C_i(P_{gi}) \quad (1)$$

$$\text{s.t. } P_{gi} - P_{di} = \sum_{j \in \mathcal{N}} V_i V_j (g_{ij} \cos \theta_{ij} + b_{ij} \sin \theta_{ij}), i \in \mathcal{N}, \quad (2)$$

$$Q_{gi} - Q_{di} = \sum_{j \in \mathcal{N}} V_i V_j (g_{ij} \sin \theta_{ij} - b_{ij} \cos \theta_{ij}), i \in \mathcal{N}, \quad (3)$$

$$P_{gi}^{\min} \leq P_{gi} \leq P_{gi}^{\max}, i \in \mathcal{N}_G, \quad (4)$$

$$Q_{gi}^{\min} \leq Q_{gi} \leq Q_{gi}^{\max}, i \in \mathcal{N}_G, \quad (5)$$

$$V_i^{\min} \leq V_i \leq V_i^{\max}, i \in \mathcal{N}, \quad (6)$$

$$P_{ij}^2 + Q_{ij}^2 \leq (S_{ij}^{\max})^2, (i, j) \in \mathcal{E}, \quad (7)$$

$$\theta_{ij}^{\min} \leq \theta_{ij} \leq \theta_{ij}^{\max}, (i, j) \in \mathcal{E}, \quad (8)$$

where: \mathcal{N} , \mathcal{N}_G and \mathcal{E} represent the sets of all buses, generation buses and transmission lines, respectively; at bus i , P_{gi} is

The work presented in this paper was supported in part by a Start-up Grant from School of Data Science (Project No. 9380118), City University of Hong Kong, and a General Research Fund from Research Grants Council, Hong Kong (Project No. 11206821). Corresponding author: Minghua Chen (Email: minghua.chen@cityu.edu.hk).

Wanjun Huang and Minghua Chen are with the School of Data Science, City University of Hong Kong. Xiang Pan is with the Department of Information Engineering, The Chinese University of Hong Kong. Steven H. Low is with the Department of Computing & Mathematical Sciences and the Department of Electrical Engineering at Caltech and the University of Melbourne, Australia.

¹ Reference [10] also learns the mapping between loads and voltages using Random Forest, but it does not consider the feasibility and needs a strong assumption to enforce power balance constraints.




Fig. 1. Schematic of the proposed DeepOPF-V.

the active generation with the cost $C_i(P_{gi})$, Q_{gi} , P_{di} and Q_{di} denote the reactive generation, active load and reactive load, respectively, and V_i and θ_i are voltage magnitude and phase angle, respectively; at branch (i, j) , g_{ij} and b_{ij} are the conductance and susceptance, respectively, P_{ij} and Q_{ij} are active and reactive power flows, respectively, and θ_{ij} is given by $\theta_{ij} = \theta_i - \theta_j$; upper and lower bounds of a certain variable x are represented by x^{\max} and x^{\min} , respectively; the branch flow limit of branch (i, j) is denoted by S_{ij}^{\max} . The AC-OPF problem aims to minimize the total generation cost in (1) with all constraints satisfied. The Kirchhoff's circuit laws are ensured by (2)-(3); active and reactive power generation limits are enforced by (4)-(5); voltage magnitude limit is ensured by (6); branch flows and voltage phase angles are restricted by (7) and (8), respectively.

B. The Proposed DNN-Based Voltage-Constrained Approach

The schematic of the proposed DeepOPF-V is shown in Fig. 1. DNNs are employed to learn the mapping between loads (P_d, Q_d) and voltages of all buses instead of only the generations or all the solution variables as in previous works. After training, for each input (P_d, Q_d) , the voltages are predicted by the well-trained DNNs instantly. Then, using the predicted voltage magnitudes \hat{V} , voltage angles $\hat{\theta}$ and the given load input (P_d, Q_d) , we can easily compute the right-hand side (RHS) of the equations in (2)-(3). The remaining solution variables \hat{P}_g, \hat{Q}_g and some auxiliary variables (\hat{P}_d, \hat{Q}_d) are then directly calculated using the obtained RHS values without the need to solve non-linear power flow equations. Specifically, for each bus i : 1) if there are only generators or loads, its required active/reactive generation (i.e., $\hat{P}_{gi}/\hat{Q}_{gi}$) or satisfied active/reactive load (i.e., $\hat{P}_{di}/\hat{Q}_{di}$) is obtained directly; 2) if there are both generators and loads, \hat{P}_{di} and \hat{Q}_{di} are set to the given loads P_{di} and Q_{di} , respectively, and then \hat{P}_{gi} and \hat{Q}_{gi} are directly calculated from (2)-(3). After obtaining \hat{P}_g , the objective function is calculated by (1). Due to the voltage prediction errors, there could be unsatisfied loads, i.e., the mismatches between (P_d, Q_d) and (\hat{P}_d, \hat{Q}_d) , which will be discussed in Section. II-D.

To reduce the size of DNNs, \hat{V} and $\hat{\theta}$ are predicted by the voltage magnitude predictor (VMP) and voltage angle predictor (VAP), respectively, to improve the training efficiency. Hence, the inputs of the VMP and of the VAP are both (P_d, Q_d) , while the outputs of the VMP and of the VAP are \hat{V} and $\hat{\theta}$, respectively². The loss functions of the VMP (denoted

as \mathcal{L}_V) and of the VAP (denoted as \mathcal{L}_θ) are formulated as

$$\mathcal{L}_V = \sum_{i \in \mathcal{N}} \|\hat{V}_i - V_i\|_2^2, \quad \mathcal{L}_\theta = \sum_{i \in \mathcal{N}} \|\hat{\theta}_i - \theta_i\|_2^2, \quad (9)$$

where: \hat{V}_i and $\hat{\theta}_i$ are predicted voltage magnitude and angle for bus i during the training, respectively; V_i and θ_i are the ground truths of \hat{V}_i and $\hat{\theta}_i$, respectively, which can be obtained by OPF solvers such as MIPS when preparing the training data.

For large power systems, we can split all buses into several groups and predict voltages for each group of buses in parallel. In this way, the DNN model size can be reduced greatly, and the training time would not increase significantly.

C. The Post-Processing Process

The post-processing process is developed herein to improve the feasibility of the predicted solution, which contains two steps. First, the inequality constraints in (4)-(8) are checked. Second, if there is violation of constraints, the related voltage magnitudes and angles are adjusted as

$$\hat{V}_{PP} = \hat{V} + \Delta V, \quad \hat{\theta}_{PP} = \hat{\theta} + \Delta \theta, \quad (10)$$

where ΔV and $\Delta \theta$ are obtained as follows. Denote inequality constraints in (4)-(8) in a compact form as $\underline{f} \leq \mathbf{f}(\theta, \mathbf{V}) \leq \bar{f}$. For each inequality constraint $f_i(\theta, \mathbf{V})$, define $\Delta f_i = \max(f_i(\theta, \mathbf{V}) - \bar{f}_i, 0) + \min(\underline{f}_i - f_i(\theta, \mathbf{V}), 0)$. Linearizing $\Delta \mathbf{f}$ around the predicted operating point $(\hat{\mathbf{V}}, \hat{\theta})$ gives

$$\begin{bmatrix} \Delta \theta \\ \Delta V \end{bmatrix} = \mathbf{F}_{\theta V}^+ \Delta \mathbf{f}, \quad \mathbf{F}_{\theta V} = \begin{bmatrix} \frac{\partial \mathbf{f}}{\partial \theta} & \frac{\partial \mathbf{f}}{\partial \mathbf{V}} \end{bmatrix}, \quad (11)$$

where $\mathbf{F}_{\theta V}^+$ is the pseudo-inverse of $\mathbf{F}_{\theta V}$. To reduce the computational burden, $\mathbf{F}_{\theta V}$ can be approximated by a constant matrix $\mathbf{F}_{\theta V}^{his}$ calculated at the average historical operating point $(\mathbf{V}^{his}, \theta^{his})$. Using (11), we adjust the values of $\Delta \theta$ and ΔV adaptively according to $\Delta \mathbf{f}$. Note that this method helps to improve but can not guarantee the satisfaction of inequality constraints. To guarantee voltage constraints, \hat{V}_{PP} are kept within the limits after adjustment.

D. Load Satisfaction

Due to the prediction errors of voltages, there could be unsatisfied loads. For example, there may be mismatches between the obtained net injections and the given loads for the bus with only loads. We note that the unsatisfied loads are also inevitable in conventional approaches [11], and 1% load-generation imbalance is considered acceptable [12]. To fully satisfy loads, controllable distributed energy sources can be applied, e.g., compensating the over/under-satisfied loads by charging/discharging batteries installed at the substation.

III. NUMERICAL EXPERIMENTS

A. Experimental Setup

Simulations are conducted on modified IEEE 118/300-bus systems and a 2000-bus test system [13]. The dataset that was used contained 40,000 samples for the 118-bus system and 60,000 samples for the 300/2000-bus systems with an 80–20%

² A lower bound for the approximation errors of the load-to-solution mapping for AC-OPF can be found in [6].

training-test split. Each sample was generated as follows. First, a load scenario was sampled randomly for each load bus from a uniform distribution of 10% variation around the default load. Then, the loads were fed into the conventional solver MIPS³ to obtain the optimal solutions as the ground truth values. By learning the mapping embedded in the training dataset, it was found that DeepOPF-V could provide solutions close to those given by the solver. To verify the effectiveness of DeepOPF-V in handling systems with large correlated load variations, real-time load data of IEEE 300-bus system generated in [14] were used, with load variations up to 42.3%.

The DNN-based model was designed on the platform of PyTorch, which consisted of fully-connected neural networks with 512, 256, 128-unit / 1024, 768, 512, 256-unit / 768, 768, 768-unit hidden layers for the 118/300/2000-bus systems. The ReLU activation function was used on the hidden layers. We applied the Adam optimizer for DNN training and set the maximum epoch and learning rate to 1000 and 0.001, respectively. The mini-batch size was set to 50/100/512 for the 118/300/2000-bus systems. For the 2000-bus system, to reduce the DNN model size, we split all buses into 10 groups evenly and predict the voltages for each group of buses in parallel. The DNNs are trained on a single GPU, which takes 286s/1676s/692s for the 118/300/2000-bus systems. Simulation tests are run on the quad-core (i7-3770@3.40G Hz) CPU workstation with 16GB RAM. The codes and data are available online [13].

The performance of DeepOPF-V is evaluated by the following metrics:

1) *Speedup*: The speedup factor η_{sp} measures the average ratio of the computation time t_{mips} consumed by MIPS to solve the original AC-OPF problem to the computation time t_{dnn} consumed by DeepOPF-V.

2) *Optimality Loss*: It measures the average relative deviation η_{opt} between the optimal objective value found by MIPS and that by DeepOPF-V.

3) *Constraint Satisfaction*: It evaluates the feasibility of the generated solutions from two aspects: constraint satisfaction ratio (i.e., the percentage of inequality constraints satisfied) and the degree of violation (i.e., the distance between the violated variable and the boundary). The constraint satisfaction ratios (the degrees of violation) of voltage magnitude, active generation, reactive generation, branch power flow and phase angle difference are denoted by η_V (Δ_V), η_{P_g} (Δ_{P_g}), η_{Q_g} (Δ_{Q_g}), η_{S_l} (Δ_{S_l}), and η_{θ_l} (Δ_{θ_l}), respectively.

4) *Load Satisfaction Ratio*: It is defined as the percentage of demanded loads satisfied. The active and reactive load satisfaction ratios are denoted as η_{P_d} and η_{Q_d} , respectively.

B. Performance Evaluation

1) *Simulation results for the 300/2000-bus systems*: The results in Table. I indicate that DeepOPF-V can speed up finding a solution to the AC-OPF problem significantly (i.e., up to three/four orders of magnitude in the 300/2000-bus systems) with negligible optimality loss (i.e., less than 0.15%). Besides,

TABLE I
SIMULATION RESULTS FOR THE 300-BUS AND 2000-BUS SYSTEMS

Metric	IEEE 300-bus system		2000-bus system	
	Before PP	After PP	Before PP	After PP
$\eta_{opt}(\%)$	0.11	0.11	0.15	0.14
$\eta_V(\%)$	100.0	100.0	100.0	100.0
$\eta_{P_g}(\%)/\eta_{Q_g}(\%)$	99.9/99.3	100.0/99.8	100.0/100.0	100.0/100.0
Δ_{P_g} (p.u.)	0.0020	0.0020	0	0
Δ_{Q_g} (p.u.)	0.3350	0.3350	0	0
$\eta_{S_l}(\%)$	100.0	100.0	99.71	99.71
Δ_{S_l} (p.u.)	0	0	0.0247	0.0247
$\eta_{\theta_l}(\%)$	100.0	100.0	100.0	100.0
$\eta_{P_d}(\%)/\eta_{Q_d}(\%)$	99.6/99.5	99.6/99.4	99.83/99.53	99.84/99.53
t_{mips}/t_{dnn} (ms)	3213.3/1.7	3213.3/2.1	39107.8/2.7	39107.8/2.9
η_{sp}	$\times 1890$	$\times 1530$	$\times 16543$	$\times 15374$

TABLE II
SIMULATION RESULTS FOR THE MODIFIED IEEE 300-BUS SYSTEM WITH REAL-TIME LOAD DATA

Metric	Before PP	After PP	
		$F_{\theta V}^{his}$	$F_{\theta V}$
$\eta_{opt}(\%)/\eta_V(\%)$	-0.01/100.0	-0.01/100.0	-0.01/100.0
$\eta_{P_g}(\%)/\Delta_{P_g}$ (p.u.)	99.6/0.0007	100.0/0	100.0/0
$\eta_{Q_g}(\%)/\Delta_{Q_g}$ (p.u.)	99.8/0.0019	100.0/0	100.0/0
$\eta_{S_l}(\%)/\eta_{\theta_l}(\%)$	100.0/100.0	100.0/100.0	100.0/100.0
$\eta_{P_d}(\%)/\eta_{Q_d}(\%)$	99.90/99.90	99.95/99.94	99.95/99.94
η_{sp}	$\times 1887$	$\times 1562$	$\times 647$

almost all loads satisfied. With regard to the feasibility of the solution, voltage and phase angle constraints are all satisfied. For the 300-bus system, the active generation and branch flow constraints are all satisfied after post-processing (PP). Almost all reactive generation constraints are satisfied with negligible violation degrees that only account for 0.03% capacities of the largest generators installed in the 300-bus system. For the 2000-bus system, the generation constraints are all satisfied. Since most branch flow constraints are already binding in the dataset, they are slightly violated due to the prediction errors, within 1% MVA rating of the branch on average.

Table. II shows that DeepOPF-V still achieves high efficiency when load variations are significant (up to 42.3%) and correlated. In addition, the performances of using $F_{\theta V}$ and the approximated matrix $F_{\theta V}^{his}$ for the PP are compared. As seen in Table. II, these two methods have the same performance except for the computational speedup. One of the main reasons is that DeepOPF-V has high prediction accuracy (i.e., the mean square prediction errors of voltage magnitudes and angles are $9.03e-5$ p.u. and $2.79e-4$ p.u., respectively). Thus, DeepOPF-V still achieves good performance without PP.

2) *Comparison with state-of-the-art approaches*: The proposed DeepOPF-V is also compared with the state-of-the-art approaches in [6] (denoted as DACOPF) and [8] (denoted as EACOPF). Parameters of DACOPF and EACOPF are set according to [6] and [8], respectively. For a fair comparison, the training/testing samples are all set to 32,000/8,000. These approaches are not compared in larger systems due to the need for lengthy training time in obtaining the solutions of [6], [8].

As shown in Table. III, all approaches have small optimality losses. However, DeepOPF-V has a much larger speedup (around three orders of magnitude) than the other approaches (around one order of magnitude). As for the feasibility of the solution, there is no violation of inequality constraints in

³ The conventional solver MIPS solves the AC-OPF problem using the interior-point method. Other solvers can also be used to generate the dataset.

TABLE III
COMPARISON RESULTS FOR MODIFIED IEEE 118-BUS SYSTEM

Metric	DeepOPF-V	DACOPF	EACOPF
$\eta_{opt}(\%)$	0.1	0.5	0.4
$\eta_V(\%) / \Delta V$ (p.u.)	100.0/0	98.6/0.0074	99.2/0.0043
$\eta_{P_g}(\%) / \Delta P_g$ (p.u.)	100.0/0	100.0/0	99.3/0.0155
$\eta_{Q_g}(\%)$	100.0	100.0	100.0
$\eta_{S_l}(\%) / \eta_{\theta_l}(\%)$	100.0/100.0	100.0/100.0	100.0/100.0
$\eta_{P_d}(\%) / \eta_{Q_d}(\%)$	99.8/99.6	100.0/100.0	100.0/100.0
η_{sp}	around $\times 1000$	around $\times 10$	around $\times 10$

DeepOPF-V, whereas there are voltage magnitude constraints violated in DACOPF and voltage and active generation constraints violated in EACOPF. It is because DeepOPF-V obtains voltages directly and thus can keep them within limits, while DACOPF and EACOPF obtain voltages by solving power flow equations using predicted generation set points, and therefore can not ensure voltage constraints. Moreover, there may be no feasible power flow solutions in DACOPF and EACOPF, which is not a concern in DeepOPF-V because power flow equations are satisfied automatically.

All loads can be fully satisfied in DACOPF and EACOPF so long as there are power flow solutions. However, there is no guarantee of the existence of power flow solutions. In this test system, 0.15% of the testing samples have no power flow solutions in EACOPF. In contrast, DeepOPF-V always guarantees to obtain power flow solutions, with a load satisfaction ratio of 99.6%, which is practically acceptable as discussed in Section II.D.

IV. CONCLUSION

We propose a DNN-based voltage-constrained approach (DeepOPF-V) to solve AC-OPF problems with high computational efficiency. It predicts voltages of all buses using a DNN-based model and then obtains all remaining variables via power flow equations, which ensures voltage and power balance constraints. Simulation results on IEEE 118/300-bus systems and a 2000-bus test system indicate that DeepOPF-V outperforms the state-of-the-art approaches in computation speedup (up to four orders of magnitude faster than conventional solver), with similar performance in optimality loss (less than 0.2%), while preserving feasibility of the solution.

REFERENCES

- [1] W. Dong, Z. Xie, G. Kestor, and D. Li, "Smart-pgsim: using neural network to accelerate ac-opf power grid simulation," in *SC20: International Conference for High Performance Computing, Networking, Storage and Analysis*. IEEE, 2020, pp. 1–15.
- [2] Y. Chen and B. Zhang, "Learning to solve network flow problems via neural decoding," *arXiv preprint arXiv:2002.04091*, 2020.
- [3] F. Hasan, A. Kargarian, and J. Mohammadi, "Hybrid learning aided inactive constraints filtering algorithm to enhance ac opf solution time," *Trans. Ind. Applicat.*, 2021.
- [4] X. Pan, T. Zhao, and M. Chen, "Deepopf: Deep neural network for dc optimal power flow," in *IEEE SmartGridComm*, 2019.
- [5] X. Pan, T. Zhao, M. Chen, and S. Zhang, "Deepopf: A deep neural network approach for security-constrained dc optimal power flow," *IEEE Trans. Power Syst.*, 2020.
- [6] X. Pan, M. Chen, T. Zhao, and S. H. Low, "Deepopf: A feasibility-optimized deep neural network approach for ac optimal power flow problems," *arXiv preprint arXiv:2007.01002v3*, 2020.
- [7] A. S. Zamzam and K. Baker, "Learning optimal solutions for extremely fast ac optimal power flow," in *IEEE SmartGridComm*, 2020.

- [8] K. Baker, "Emulating ac opf solvers for obtaining sub-second feasible, near-optimal solutions," *arXiv preprint arXiv:2012.10031*, 2020.
- [9] M. Chatzos, F. Fioretto, T. W. Mak, and P. Van Hentenryck, "High-fidelity machine learning approximations of large-scale optimal power flow," *arXiv preprint arXiv:2006.16356*, 2020.
- [10] J. Rahman, C. Feng, and J. Zhang, "Machine learning-aided security constrained optimal power flow," in *IEEE PESGM*, 2020.
- [11] D. K. Molzahn and I. A. Hiskens, "Sparsity-exploiting moment-based relaxations of the optimal power flow problem," *IEEE Trans. Power Syst.*, vol. 30, no. 6, pp. 3168–3180, 2014.
- [12] R. Salgado, C. Moyano, and A. Medeiros, "Reviewing strategies for active power transmission loss allocation in power pools," *Int. J. Electr. Power Energy Syst.*, vol. 26, no. 2, pp. 81–90, 2004.
- [13] W. Huang, "Main codes and data for deepopf-v: Solving ac-opf problems efficiently," GitHub, 2021, <https://github.com/wanjunhuang/hwjcode>.
- [14] Y. Tang, K. Dvijotham, and S. Low, "Real-time optimal power flow," *IEEE Trans. Smart Grid*, vol. 8, no. 6, pp. 2963–2973, 2017.