DeepOPF: A Feasibility-Optimized Deep Neural Network Approach for AC Optimal Power Flow Problems

Xiang Pan, Student Member, IEEE, Minghua Chen, Fellow, IEEE, Tianyu Zhao, and Steven H. Low, Fellow, IEEE

Abstract-To cope with increasing uncertainty from renewable generation and flexible load, grid operators need to solve alternative current optimal power flow (AC-OPF) problems more frequently for efficient and reliable operation. In this paper, we develop a Deep Neural Network (DNN) approach, called DeepOPF, for solving AC-OPF problems in a fraction of the time used by conventional iterative solvers. A key difficulty for applying machine learning techniques for solving AC-OPF problems lies in ensuring that the obtained solutions respect the equality and inequality physical and operational constraints. Generalized a prediction-and-reconstruction procedure in our previous studies, DeepOPF first trains a DNN model to predict a set of independent operating variables and then directly compute the remaining ones by solving the power flow equations. Such an approach not only preserves the power-flow balance equality constraints but also reduces the number of variables to be predicted by the DNN, cutting down the number of neurons and training data needed. DeepOPF then employs a penalty approach with a zero-order gradient estimation technique in the training process towards guaranteeing the inequality constraints. We also drive a condition for tuning the DNN size according to the desired approximation accuracy, which measures its generalization capability. It provides theoretical justification for using DNN to solve AC-OPF problems. Simulation results for IEEE 30/118/300-bus and a synthetic 2000-bus test cases demonstrate the effectiveness of the penalty approach. They also show that DeepOPF speeds up the computing time by up to two orders of magnitude as compared to a state-of-the-art iterative solver, at the expense of <0.2% cost difference.

Index Terms—Deep learning, Deep neural network, AC optimal power flow.

NOMENCLATURE

Variable	Definition
\mathcal{N}	Set of buses, $N \triangleq \operatorname{card}(\mathcal{N})$.
${\mathcal G}$	Set of P-V buses.
\mathcal{D}	Set of P-Q buses.
${\mathcal E}$	Set of branches.
P_{Gi}	Active power generation at bus <i>i</i> .
P_{Gi}^{\min}	Minimum active power generation at bus <i>i</i> .
P_{Gi}^{\max}	Maximum active power generation at bus <i>i</i> .
P_{Di}	Active power load at bus <i>i</i> .
Q_{Gi}	Reactive power generation at bus <i>i</i> .
Q_{Gi}^{\min}	Minimum reactive power generation at bus i .
Q_{Gi}^{\max}	Maximum reactive power generation at bus <i>i</i> .

This work was supported in part by a General Research Fund from Research Grants Council, Hong Kong (Project No. 11203122), an InnoHK initiative, The Government of the HKSAR, and Laboratory for AI-Powered Financial Technologies, and in part by NSF through grants ECCS 1931662, Caltech Resnick, S2I funds, and C3.ai/UC Berkeley.

Xiang Pan is with Department of Information Engineering, The Chinese University of Hong Kong, Hong Kong 999077, Hong Kong. Minghua Chen is with School of Data Science, City University of Hong Kong, Hong Kong 999077, Hong Kong. Tianyu Zhao is with Lenovo Machine Intelligence Center, Lenovo, Hong Kong 999077, Hong Kong. Steven H. Low is with Department of Computing and Mathematical Sciences and Department of Electrical Engineering, California Institute of Technology, Pasadena, CA 91125, USA. Corresponding author: Minghua Chen (minghua.chen@cityu.edu.hk).

Q_{Di}	Reactive power load at bus <i>i</i> .
V_i	Complex voltage at bus i (includes the magnitude $ V_i $
	and the phase angle θ_i , i.e., $V_i = V_i \angle \theta_i$).
V_i^{\min}	Minimum voltage magnitude at bus <i>i</i> .
V_i^{\max}	Maximum voltage magnitude at bus <i>i</i> .
y_{ij}	Complex admittance of the branch $(i, j) \in \mathcal{E}$.
S_{ii}^{\max}	Transmission limit of the branch $(i, j) \in \mathcal{E}$.

1

We use $card(\cdot)$ to denote the size of a set. For P-Q buses, the corresponding generator output and the operating bound are set to 0. Without loss of generality, we set bus 0 as the slack bus.

I. INTRODUCTION

Optimal power flow (OPF) problem, first posed by Carpentier in 1962 [1], is central to power system operation and concerns more than ten billion dollars each year in the U.S. alone [2]. It optimizes particular system objectives, e.g., generation cost, subject to power-flow balance and operational constraints regarding the generation, voltage, and branch flow.

Conventionally, OPF problems are mainly concerned at the transmission grid level, and the distribution grids are modeled as passive load buses with aggregated demand from different users. The recent endeavors of grid modernization and accommodating high penetration of distributed energy resources (DERs), such as solar photovoltaic and wind generating units, convert the buses in the distribution grids into more active ones. While they provide enormous control flexibility to reduce the cost of grid operation, the intermittent and uncertain nature of DERs introduces significant fluctuations and randomness in power injections. To cope with the fluctuation and uncertainty, the grid operators usually solve stochastic OPF problems frequently to efficiently and reliably maintain the power supply and demand balance. Specifically, system operators often generate a large number of scenarios based on different load prediction (e.g., more than 1000) and solve the corresponding standard OPF problems (one for each scenario) in order to obtain a stochastically optimized solution [3].

However, conventional iteration-based solvers may not be able to solve OPF problems fast enough for the purpose [4]. For example, suppose a single large-scale AC-OPF problem can be solved quickly (e.g., state-of-the-art solvers can return the solution in one second for power network with hundreds of buses [5]), solving 1000 AC-OPF problems needs more than 10 minutes, which can be too slow for adjusting system operating points in response to the changes of renewable power injection [6]. It is thus crucial to develop efficient OPF solvers for cost-effective and reliable modern power system operation.

Recently, learning-based approaches for solving OPF problems have received substantial attention. The works in [7]–[9] develop the first DNN schemes to *directly* generate feasible and close-to-optimal solutions for (security-constrained) DC-OPF problems in a fraction of the time used by iterative solvers. The idea is to leverage the universal approximation [10] capability of DNNs to learn the mapping between load input and OPF solutions. Then one can pass the loads through the trained DNN to instantly obtain a quality solution. The works suggest the potential of using deep learning in solving OPF problems and attract a variety of further studies [11]–[16], some beyond the OPF problem [17]. Learning-based approaches have also been developed to facilitate the solving process for OPF problems, by, e.g., determining active/inactive constraints to reduce the problem size [4], [18]–[22] or speeding up the iterations in conventional solvers [23]–[28]. We present detailed discussions of related works in Sec. II.

In this paper, we generalize the 2-stage approach in [7], [8] to develop a DNN scheme for solving AC-OPF problems directly.¹ As compared to using DNN to solve DC-OPF problems [7], [8], developing DNN schemes for AC-OPF problems face the following unique challenges.

- It is non-trivial to ensure the *feasibility* of the generated solution, i.e., ensuring the DNN solution satisfies the non-convex power-flow balance equations and the operation limits simultaneously.
- It is challenging to guide the DNN design (i.e., setting the number of hidden layers and the number of neurons per layer) to achieve the desired performance.

In this paper, we carry out a comprehensive study on the above challenges and make the following contributions.

 \triangleright After briefly reviewing AC-OPF problem in Sec. III, we develop a DNN approach for solving AC-OPF problem directly by generalizing the 2-stage Predict-and-Reconstruct (PR2) framework in [7], [8] to AC-OPF setting in Sec. IV-C. To guarantee the power-flow balances, we first train a DNN model to predict a set of independent operating variables and reconstruct the remaining ones by solving the AC power flow equations. We then employ a penalty approach in training the DNN so that the reconstructed solutions (generation, voltages, and branch flows) respect the corresponding operation limits. Due to the non-linearity of the AC power flow equations, it is difficult to compute the penalty gradient. We further apply a zero-order optimization technique in the training algorithm to compute the penalty gradients efficiently.

▷ We characterize the load-to-solution mapping and study how well could a DNN learn such a mapping in Sec. V. We first show that the load-to-solution mapping is continuous and differentiable almost everywhere when the optimal solution is unique, adding a new understanding to the AC-OPF literature. Consequently, by the universal approximation capability [10], DNN can approximate the load-to-solution mapping arbitrarily well as the number of neurons increases. We further derive a condition for tuning the size of the DNN according to the desired approximation accuracy. To our best knowledge, these results provide the first theoretical justification of using DNN to solve AC-OPF problem. \triangleright We carry out simulations on IEEE 30/118/300-bus and a synthetic 2000-bus test cases and summarize the results in Sec. VI. DeepOPF speeds up the computing time by up to two orders of magnitude with <0.2% cost difference as compared to Pypower [33]. The comparison results with recent learningbased schemes show the effectiveness of the penalty approach in improving DNN solutions' feasibility. We also observe that the DNN model trained with the estimated gradient from zeroorder techniques achieves a similar or better feasibility rate than that trained with exact gradient by exploiting the implicit function theorem (see, e.g. [17]), which can be of independent interest. Due to the space limitation, all proofs are in the technical report [34].

II. RELATED WORK

Leveraging learning techniques to solve the OPF problem is becoming an active area of research. As seen in Table I, existing supervised-learning based works can be grouped into two orthogonal categories: the hybrid approach [4], [18]-[28] and the stand-alone approach [7]–[9], [11]–[16], [29]–[32]. The hybrid approach applies the learning technique to accelerate the solving process of conventional methods. Some works for DC-OPF focus on learning the active/inactive constraints that can maintain the optimality and achieve speedup by reducing the problem size [4], [18]–[22]. Others predict warm-start points or gradient for iteration to accelerate the solving process by providing initial points close to the optimal or replacing the computationally expensive gradient computation with a fast neural-network predictor [23]-[28]. The hybrid approach's limitations lie in the limited speedup performance due to the inevitable iteration process. For example, the speedup performance reported in [24]-[26] for the hybrid approach predicting warm-start points is up to $4 \times$ for a 2000-bus test case while the stand-alone scheme reported in this paper achieves up to $123 \times$ speedup for the same 2000-bus test case.

The stand-alone approach directly generates solutions to the OPF problem. Some works [12], [15], [16], [29]–[32] use NN to predict all the variables and model the constraint violation into the loss function. Yet the obtained solutions suffer from the in-feasibility issue as the equality constraints may not be satisfied due to prediction errors. Meanwhile, [7]-[9] propose a PR2 framework for solving the (security-constrained) DC-OPF problem, which predicts a subset of the variables and reconstructs the remaining ones by leveraging the equality constraints. They also integrates the penalty term into the training process to pursue the inequality constraints satisfaction. The authors in [14] apply the PR2 framework to design a DNN to generate solutions to AC-OPF problems, but it does not consider the line limit constraints and the generated solutions may not be feasible. [32] also designs a framework similar to the PR2 one to solve AC-OPF problem, but it does not consider the inequality constraints' violation and may result in in-feasible solutions.

Besides the supervised-learning approach, there is an emerging line of research [17], [35], [36] on developing an unsupervised/reinforcement learning framework for solving the OPF problem. For example, [17] trains a DNN to minimize the generation cost and the penalty regarding constraints

¹We note that there are also two independent works [13] and [14] applying the 2-stage approach in [7] to solve AC-OPF problems. We discuss the difference and similarity in Sec. II and compare the performance in Sec. VI.

Catagory	Approach	Existing Study	Prot	olem	Metrics in Consideration			
Category	Арріоасн	Existing Study	DC-OPF	AC-OPF	Feasibility	Optimality	Speedup	
	Determining active constraints	[18]	√		×	\checkmark	\checkmark	
	Determining active constraints	[4], [19], [20]	\checkmark		\checkmark	√	√	
Hybrid	Determining inactive constraints	[21]	\checkmark		×	\checkmark	√	
	Determining mactive constraints	[22]		\checkmark	×	\checkmark	\checkmark	
	Dradiating warm start point	[23]	 ✓ 		\checkmark	√	√	
	redicting warm-start point	[24]–[26], [28]		\checkmark	\checkmark	√	\checkmark	
	Predicting gradient in iterative algorithms	[27]		\checkmark	×	\checkmark	\checkmark	
Stand-alone	Learning the load solution manning and	[7]–[9], [11], [29]	~		\checkmark	√	√	
	generating solutions directly from load inputs	[12]–[16], [30]–[32]		\checkmark	×	\checkmark	\checkmark	
	generating solutions uncerty from four inputs	This work		\checkmark	\checkmark	\checkmark	\checkmark	

TABLE I: Summary of existing studies on machine learning for solving OPF problems.

violations, which exploit the implicit function theorem to compute the penalty gradient for tuning the DNN's parameters. Although both works do not need to prepare the ground truth, which can be computational expensive, they have some certain limitations. [17] does not consider the line limit constraints, and [35], [37] may lead to load dissatisfaction.

In this paper, we generalize the PR2 framework in our previous work [7]–[9] and integrate the penalty approach for solving AC-OPF problems directly. The penalty approach has been used in [7]–[9], [15], [17], [29], [30], [32]. A key challenge of applying the penalty approach to the AC-OPF setting lies in that there does not exist an explicit expression between the predicted variables and the reconstructed variables due to the non-linear AC power flow equations for gradient-based training method. This makes it difficult to compute the penalty gradient. One contribution of this paper is to address the challenge of obtaining the penalty gradients efficiently by a zero-order technique during training, to improve the feasibility performance. We also evaluate the performance of DeepOPF on medium-/large-scale cases with up to 2000 buses.

III. AC-OPF PROBLEM

We study the standard AC-OPF problem with the bus injection $model^2$ as follows:

$$\min \sum_{i=1}^{N} C_i \left(P_{Gi} \right) \tag{1}$$

s.t.
$$\sum_{(i,j)\in\mathcal{E}} \operatorname{Re}\left\{V_i\left(V_i^* - V_j^*\right)y_{ij}^*\right\} = P_{Gi} - P_{Di},$$
 (2)

$$\sum_{(i,j)\in\mathcal{E}} \operatorname{Im}\left\{V_{i}\left(V_{i}^{*}-V_{j}^{*}\right)y_{ij}^{*}\right\} = Q_{Gi} - Q_{Di}, \quad (3)$$

$$P_{Gi}^{\min} \le P_{Gi} \le P_{Gi} \le P_{Gi}^{\max}, i \in \mathcal{N}, \tag{4}$$

$$Q_{Gi}^{\min} \le Q_{Gi} \le Q_{Gi}^{\max}, i \in \mathcal{N},\tag{5}$$

$$V_i^{\min} \le |V_i| \le V_i^{\max}, i \in \mathcal{N},\tag{6}$$

$$|V_i(V_i^* - V_j^*) y_{ij}^*| \le S_{ij}^{\max}, (i, j) \in \mathcal{E},$$
(7)

var. $P_{Gi}, Q_{Gi}, V_i, i \in \mathcal{N},$

ŝ

where $\operatorname{Re}\{z\}$, $\operatorname{Im}\{z\}$, and z^* denote the real part, imaginary part, and the conjugate of z, respectively. The typical objective is to minimize the total cost of active power generations,

²There are two equivalent models in the OPF problem, namely the bus injection model and the branch flow model [38]. The DeepOPF approach applies to both models. We focus on the bus injection model in this paper.

where $C_i(\cdot)$ is the individual generation cost function and is commonly quadratic. The constraints are the power-flow balance equations in (2) and (3), the active and reactive generation limits in (4) and (5), the voltage magnitude limit in (6), and the branch flows limits in (7). We note that (P_{D_i}, Q_{D_i}) is the net load of bus *i*, which is the difference between the actual electricity demand and the DERs power generation, e.g., solar or wind generation, at the bus.

As discussed in Sec I, grid operators may need to solve stochastic AC-OPF problems in practice, which requires one to solve a large number of standard AC-OPF problems efficiently. However, the AC-OPF problem is NP-hard [39] and non-convex. Consequently, no solvers can solve general AC-OPF problems exactly in polynomial time unless $P = NP.^3$ This observation motivates the studies of reducing the time for solving AC-OPF problems.

Recently, there has been active research in employing DNN to solve OPF problems directly, in a fraction of the time used by iterative solvers; see detailed discussions in Sec. II. The idea is to leverage the approximation capability of DNNs [10] to learn the load-solution mapping of the OPF problem. Then one can feed the load to the DNN to obtain a solution instantly. In this paper, we generalize the 2-stage approach in [7], [8] to develop a DNN scheme to learn the load-solution mapping for solving AC-OPF problems directly with optimized solution feasibility.⁴

IV. A FEASIBILITY-OPTIMIZED DEEP NEURAL NETWORK APPROACH FOR AC-OPF

A. Overview of DeepOPF

Fig. 1 presents the predict-and-reconstruct (PR2) framework of DeepOPF. The idea is to train a DNN model to predict a set of independent operating variables and then directly compute the remaining dependent variables by solving AC powerflow equations. The proposed DeepOPF guarantees that the

³Note that AC-OPF problems under specific settings may still be polynomial-time solvable. For example, some existing works, e.g., [40], characterize sufficient conditions under which AC-OPF problems can be solved exactly in polynomial time by convexification.

⁴We note that the non-convex AC-OPF problem may admit multiple optimal solutions, thus multiple load-solution mappings. Meanwhile, it is empirically observed that (i) there is a unique solution that satisfies the operational constraints given a "reasonable" load region [6] and (ii) current state-of-the-art solvers can obtain close-to-optimal OPF solutions. Based on these observations, we assume the load-solution mapping generated by the state-of-the-art solver (Pypower in our case) is unique and regarded as the mapping to be learned by the DNN scheme.



Fig. 1: The predict-and-reconstruct framework for designing DNN solvers for AC-OPF problems. ⁵The DNN is trained to predict a selected set of independent variables, as listed in Table II. The remaining dependent variables are reconstructed via solving the non-linear AC power-flow equations.

power-flow equality constraints are satisfied and reduces the dimension of mapping to learn, subsequently cutting down the size of the DNN and the amount of training data needed.

While the power flows are balanced by following the PR2 framework, the fundamental difficulty lies in ensuring that the obtained solutions satisfy generations' operation limits, voltages, and branch flows constraints. Most recent studies in this area for AC-OPF did not consider this hurdle for ensuring feasibility, as discussed in Table I. In general, there exist two methods to tackle this issue. One is to extend the preventive learning framework for DC-OPF [9], where we strengthen the operating constraints used in training, therefore anticipating the resulting predicted solutions remain feasible to the DC-OPF problem with default constraints even with approximation errors. However, it is non-trivial to determine how much we should calibrate the operating constraints for AC-OPF problem without reducing the load input region. The other is to integrate our PR2 framework with the penalty approach [8] by adding the constraints-related term in the loss function during the training process. The penalty approach excels in that it does not need to reduce the supportable load region. However, as we will see in Sec. IV-F, it requires us to run a gradient-like algorithm without access to the gradient information directly. The proposed DeepOPF leverages zero-order optimization techniques to address the issue.

B. Data Preparation

To train and test the DNN model, we sample the training and test load data, i.e., P_{D_i} and Q_{D_i} , $i \in \mathcal{N}$ within a given range of the default value, uniformly at random, which helps avoid the over-fitting issue. The sampling data is then fed into the traditional AC-OPF solver to obtain reference solutions. Following the common practice, we normalize each dimension of training data with the standard variance and mean of the corresponding dimension before training.

C. Prediction and Reconstruction

We summarize the set of independent variables (to predict) and the remaining dependent variables (to reconstruct) for each type of bus in Table II. As seen, DNN predicts the voltage phase angle and voltage magnitude on the slack bus, θ_0 and $|V_0|$, and the set of the active power generation and the voltage magnitude for the P-V buses, i.e., P_{Gi} and $|V_i|, i \in \mathcal{G}$.

TABLE II: The selected independent and dependent variables.

Type of bus	Slack	P-Q	P-V
Set of independent variables	$\theta_0, V_0 $	$P_{Di}, Q_{Di}, \\ i \in \mathcal{D}$	$P_{Gi}, V_i , \\ i \in \mathcal{G}$
Set of dependent variables	P_{G0}, Q_{G0}	$\begin{array}{c} \theta_i, V_i , \\ i \in \mathcal{D} \end{array}$	$\begin{array}{c} \theta_i, Q_{Gi}, \\ i \in \mathcal{G} \end{array}$

Every variable in Table II to be predicted by the DNN, denoted by x_{pred} , is related to a operating constraints, i.e., $x^{\min} \leq x_{pred} \leq x^{\max}$. Similar to [7], [8], [14], we associate with it a one-to-one corresponding scaling factor by

$$c_{pred} = s_{pred} \cdot \left(x^{\max} - x^{\min} \right) + x^{\min}, \tag{8}$$

where s_{pred} is the scaling factor. The DNN will predict s_{pred} and compute x_{pred} by (8). In our design, the Sigmoid function [41] is applied as the activation function of the output layer to ensure the predicted scaling factor to within (0, 1).

We reconstruct the remaining dependent variables listed in Table II by solving the nonlinear AC power-flow equations by the widely-used Newton's method [42], with the predicted independent variables as inputs. It is well understood that there exist multiple solutions to the AC power flow equations. Newton's method or similar iterative algorithms generate different solutions to AC power flow equations using different initial points [42]. Meanwhile, the convergence of Newton's method also depends on the chosen initial points. In our design, we set Newton's method's initial points as the average values of the dependent variables in the historical/training data. In our simulations in Sec. VI, we observed that Newton's method with such initialization always converges.

D. DNN Model

s

In DeepOPF, we design the DNN model based on the multi-layer feed-forward neural network structure:

$$\mathbf{s}_0 = [\mathbf{P}_D, \mathbf{Q}_D], \tag{9}$$

$$\mathbf{s}_{i} = \sigma \left(W_{i} \mathbf{s}_{i-1} + \mathbf{b}_{i} \right), \forall i = 1, ..., L, \quad (10)$$

$$\mathbf{s}_{pred} = \sigma' \left(W_{L+1} \mathbf{s}_L + \mathbf{b}_{L+1} \right), \tag{11}$$

where $\mathbf{P}_D = [P_{D_i}, i \in \mathcal{N}]$ and $\mathbf{Q}_D = [Q_{D_i}, i \in \mathcal{N}]$ are the active and reactive load vector, consisting DNN's input \mathbf{s}_0 . \mathbf{s}_i is the output vector of the *i*-th hidden layer, depending on matrices W_i , biases vectors \mathbf{b}_i and the (i - 1)-th layer's output \mathbf{s}_{i-1} . W_i and \mathbf{b}_i are subject to the DNN design. L is the number of hidden layer. $\sigma(\cdot)$ and $\sigma'(\cdot)$ are ReLU activation function used in the hidden layers and the Sigmoid action function used in output layer, respectively. In our simulation, we use a DNN with two hidden layers; thus L = 2. The DNN predicts voltage magnitude on the slack bus, the active power generation, and the voltage magnitude on the P-V buses. Thus, the output dimension of DNN model is $2 \cdot \operatorname{card}(\mathcal{G}) + 1$.

E. Penalty Approach based Training Scheme

After constructing the DNN model, we design a loss function to guide the training. For each instance in the training data set, the loss function consists of two parts. The first part is the prediction error, which is computed with the squared ℓ_2

⁵The framework is generalized from the one for DC-OPF problems proposed in [7], [8], by replacing the DC-PF equations with AC power flow equations. It is also used in two independent works [14] and [13].

norm between the generated scaling factors vector \mathbf{s}_{pred} and the reference vector \mathbf{s}_{ref} :

$$\mathcal{L}_{pred} = \frac{1}{2 \cdot \operatorname{card}(\mathcal{G}) + 1} \|\mathbf{s}_{pred} - \mathbf{s}_{ref}\|_2^2.$$
(12)

The second part is a penalty term to capture the violation of the inequality constraints in AC-OPF formulation, including the generation limits, the voltage magnitude constraints, and the branch flow limits.⁶ For the reconstructed variable in Table II, say x_{rec} , the corresponding penalty is defined by:

$$p(x_{rec}) = \max(x_{rec} - x_{rec}^{\max}, 0) + \max(x_{rec}^{\min} - x_{rec}, 0),$$
(13)

which gives a positive penalty if x_{rec} is outside the feasible region $[x_{rec}^{\min}, x_{rec}^{\max}]$ and zero otherwise. The overall penalty in the loss function is the average penalty of the reconstructed variables as follows:

$$\mathcal{L}_{pen} = \frac{1}{\operatorname{card}(\mathcal{E})} \sum_{(i,j)\in\mathcal{E}} p\left(S_{rec,ij}\right) + \frac{1}{\operatorname{card}(\mathcal{D})} \sum_{i\in\mathcal{D}} p\left(|V_{rec,i}|\right) + \frac{1}{\operatorname{card}(\mathcal{G})} \sum_{i\in\mathcal{G}} p\left(Q_{rec,Gi}\right) + p\left(P_{rec,G0}\right) + p\left(Q_{rec,G0}\right),$$
(14)

where $p(S_{rec,ij})$, $p(|V_{rec,i}|)$, $p(Q_{rec,Gi})$, $p(P_{rec,G0})$ and $p(Q_{rec,G0})$ represent the violation for each reconstructed branch flow, the violation for each reconstructed voltage magnitude at P-Q buses, the violation for each reconstructed reactive power generation at P-V buses, and the violation for the reconstructed active/inactive power generation at the slack bus, respectively. The overall loss function is given as:

$$\mathcal{L} = w_1 \cdot \mathcal{L}_{pred} + w_2 \cdot \mathcal{L}_{pen},\tag{15}$$

where w_1 and w_2 are positive weighting factors used to balance the prediction error and the penalty during the training. The training processing is to minimize the average loss of the training data by adjusting the DNN's parameters W_i and \mathbf{b}_i :

$$\min_{W_i, \mathbf{b}_i, i=1, \dots, L} \frac{1}{\operatorname{card}\left(\mathcal{T}\right)} \sum_{k \in \mathcal{T}} \mathcal{L}_k,$$
(16)

where \mathcal{T} is the training data-set, and \mathcal{L}_k is the loss of the training data with index k.

F. Zero-order Optimization Technique for Penalty Approach

It is common to apply the first-order gradient-based schemes, e.g., the stochastic gradient descent (SGD) algorithm, to solve (16) in training. This requires the gradients information i.e., $\nabla \mathcal{L}_{pred}$ and $\nabla \mathcal{L}_{pen}$, with respect to W_i and \mathbf{b}_i . We can first compute $\nabla \mathcal{L}_{pred}$ and $\nabla \mathcal{L}_{pen}$ w.r.t DNN's output (\mathbf{s}_{pred}), and apply chain rule to get the gradients w.r.t W_i and \mathbf{b}_i . As \mathcal{L}_{pred} only depends on \mathbf{s}_{pred} , we directly compute the corresponding $\nabla \mathcal{L}_{pred}(\mathbf{s}_{pred})$ according to (12). However, it is hard to compute $\nabla \mathcal{L}_{pen}(\mathbf{s}_{pred})$ as there does not exist an explicit expression between the predicted variables and the reconstructed variables, making it difficult to compute the penalty gradient w.r.t. the DNN's output directly. It is the key challenge in applying the penalty approach in training DNN for solving AC-OPF problems.

We address the challenge as follows. We estimate the gradients $\nabla \mathcal{L}_{pen}$ w.r.t DNN's output by a two-point zero-order optimization technique [43], [44] as:

$$\hat{\nabla} \mathcal{L}_{pen} \left(\mathbf{s}_{pred} \right) = \frac{d \cdot \mathbf{v}}{2\delta} [\mathcal{L}_{pen} \left(\mathbf{s}_{pred} + \mathbf{v}\delta \right) - \mathcal{L}_{pen} \left(\mathbf{s}_{pred} - \mathbf{v}\delta \right)], (17)$$

where d is the output dimension of the DNN model, $\delta > 0$ is a smooth parameter, and v is a vector sampled uniformly at random on the unit ball. The following proposition shows the effectiveness of the zero-order method for gradient estimation.

Proposition 1. Assumed \mathcal{L}_{pen} : $\mathbb{R}^d \mapsto \mathbb{R}$ is differentiable, the gradient estimator in (17) is unbiased, *i.e.*,

$$\lim_{d\to 0} \mathbf{E}_{\mathbf{u}} \left(\hat{\nabla} \mathcal{L}_{pen} \left(\mathbf{s}_{pred} \right) \right) = \nabla \mathcal{L}_{pen} \left(\mathbf{s}_{pred} \right).$$

We discuss the advantage of the two-point zero-order optimization technique in the following. First, it is more efficient than the standard gradient estimation method. The method would solve the AC power flow equations many times by uniform sampling on the unit ball so as to compute gradient numerically. It is computationally expensive. In contrast, the two-point gradient estimator only requires solving the AC power flow equations twice regardless of the input space dimensions, which substantially reduces the computation burden. Second, the two-point scheme is more efficient than other zeroorder optimization techniques, e.g., one-point or multi-point methods [44], in that the two-point scheme usually achieves a better trade-off between computation efficiency and estimation variance in practice. Further, it is straightforward to implement the gradient estimator in (17).

After obtaining $\hat{\nabla}\mathcal{L}_{pen}(\mathbf{s}_{pred})$, we compute the gradient for the entire loss w.r.t. the output of DNN as $\hat{\nabla}\mathcal{L}(\mathbf{s}_{pred}) = w_1 \nabla \mathcal{L}_{pred}(\mathbf{s}_{pred}) + w_2 \hat{\nabla}\mathcal{L}_{pen}(\mathbf{s}_{pred})$. We then use the backpropagation algorithm [41] to compute the loss gradient with respect to W_i and \mathbf{b}_i for the *i*th layer in the DNN model. The outline of the process is summarized in Algorithm 1.

We note that the proposed algorithm is essentially a variant of SGD algorithms. Research [45] suggests the following general conditions for the convergence of SGD algorithms: (i) The gradient estimation is an unbiased approximation of the exact gradient; (ii) The variance of estimation error is upper-bounded by a constant; (iii) The exact gradient is Lipchitz-continuous w.r.t the input. In our setting, condition (i) holds according to Proposition 1. However, it is difficult to check whether conditions (ii) and (iii) hold without the explicit expression of the penalty gradient, which we leave as a future direction.⁷ Instead, we develop a DNN training

⁶We note that by using the Predict-and-Reconstruct framework, DeepOPF guarantees the power-flow balance equality constraints always satisfied.

⁷Although one can still compute the penalty gradient by applying the implicit function theorem (see, e.g., [17]), in the absence of an explicit expression of the penalty function to the predicted variables, the computation involved in checking the two conditions are non-trivial. In particular, the computation involves the inversion operation for the Jacobian matrix of the reconstructed variables w.r.t. the predicted variables, which is not a constant matrix. To check conditions (ii) and (iii), we need to obtain the upper bound of the norm of the exact gradient. This in turn needs us to bound the maximum singular value of the inverse Jacobian matrix, which is non-trivial as we need to solve a non-convex optimization to obtain the bound.

Algorithm 1: Proposed training algorithm

Input: DNN with initial parameter W_i^0 , b_i^0 for layer *i*, learning rate η , training epochs T, data-set T **Output:** Trained DNN with parameters W_i^T and b_i^T 1 t = 02 for t < T do Shuffle the training data set T; 3 for each batch $\mathcal{B} \subset \mathcal{T}$ do 4 Compute the loss gradient via zero-order 5 technique w.r.t DNN's output: $\nabla \hat{\mathcal{L}}^{t} = \frac{1}{\operatorname{card}\left(\mathcal{B}\right)} \sum_{j \in \mathcal{B}} \nabla \hat{\mathcal{L}}_{j}\left(\mathbf{s}_{pred,j}\right)$ 6 Update W_i and b_i by back-propagation: $\begin{aligned} W_i^{t+1} &= W_i^t - \eta \cdot \nabla \hat{\mathcal{L}}^t \left(W_i^t \right) \\ b_i^{t+1} &= b_i^t - \eta \cdot \nabla \hat{\mathcal{L}}^t \left(b_i^t \right) \end{aligned}$ t = t + 17

algorithm using the two-point gradient estimation technique and empirically observe that the algorithm converges in our setting. We also compare and discuss the performance of the DNN models that are trained with zero-order optimization technique and that based on implicit function theorem (see, e.g. [17]) in Sec. VI-D.

G. Feasibility Test and Recovery

As discussed in Sec IV-C, DeepOPF predicts a set of independent variables in the AC-OPF solution and reconstructs the remaining ones by solving AC power flow equations. As such, the AC power flow equality constraints are guaranteed to be satisfied. Meanwhile, due to the inherent DNN approximation error, the obtained AC-OPF solution may not satisfy the inequality constraints, i.e., generations/voltages/branchflow limits, even with the penalty approach in place.

Thus, after obtaining the solution, we first verify its feasibility by checking if it violates any inequality constraints. We output the solution if it passes the feasibility test. Otherwise, we run a conventional solver with the solution as a warm-start point to recover a feasible solution. If no feasible solution can be recovered, the particular load input is not supportable.

We note that the feasibility-recovery step is usually faster than solving AC-OPF problems directly, especially when the warm-start point is close to the optimal [24]-[26]. Simulation results in Sec. VI show the obtained solutions from DeepOPF with the penalty approach are feasible for most of the time (> 99%) and do not need to go through feasibility recovery. The overall speedup performance is decent, with feasibilityrecovery in place.

V. ANALYSIS OF DEEPOPF

In this section, we show that the AC-OPF load-to-solution mapping is continuous when the optimal solution is unique, adding new understanding to the AC-OPF problem. We then show that DNN can approximate such a mapping arbitrarily well as the number of neurons increases.

A. Understanding the AC-OPF Load-Solution Mapping

Let $f^*(\cdot)$ denote the mapping from the load, denoted by $\mathbf{D} := (P_{Di}, Q_{Di}, i \in \mathcal{N}),$ to the optimal solution of the AC-OPF problem, denoted by $\mathbf{X}^* := (P_{Gi}^*, Q_{Gi}^*, |V_i^*|, \theta_i^*, i \in \mathcal{N}).$ Noted that the AC-OPF problem may have multiple optimal solutions for a given load input and in general $f^*(\cdot)$ may be a set of mappings and \mathbf{X}^* may be a set of optimal solutions. Here we abuse the notation a bit to ease the following discussions. Before proceeding, we recall the definition of set of Lebesgue measure zero.

Definition 2. A set $S \subset \mathbb{R}^n$ has Lebesgue measure zero if for every $\epsilon > 0$, S can be covered by a countable family of *n*-cubes, the sum of whose measures is less than ϵ .

Taking 2-dimensional space as example, a set in the space has Lebesgue measure zero means its area is 0; thus a randomlyselected load input lies in the set with zero probability. The following theorem gives a useful observation on the smoothness of $f^*(\cdot)$ when the optimal solution is unique.

Theorem 3. Assumed the load domain is compact and X^* is unique for any given **D** in the load domain, $f^*(\cdot)$ is a continuous mapping. Further, the Hessian of $f^*(\cdot)$ exists everywhere over the load domain except for a set of Lebesgue measure zero.

We noted the unique optimal solution to AC-OPF problem is an empirical observation for networks, e.g., a distribution network with a tree topology, and there exist sufficient conditions to guarantee the uniqueness of the optimal solution (see, e.g., [40]). Theorem 3 says that, when the optimal solution is unique, the load-to-solution mapping $f^*(\cdot)$ is continuous everywhere and differentiable almost everywhere, e.g., it cannot be step or Dirichlet functions/mappings, adding new understanding to the AC-OPF load-to-solution mapping in the literature. This observation justifies the endeavors of leveraging DNN to learn the continuous load-to-solution mapping for a given power network. Specifically, there always exists a DNN-learned mapping $f(\cdot)$ whose approximation error to the continuous mapping $f^*(\cdot)$ can be arbitrarily small, as the number of neurons increases [46].

B. DNN Approximation Error of Load-to-Solution Mapping

We further establish results for DNN approximation error to the load-to-solution mapping. Without loss of generality, we focus on the one-dimension output case in the follows discussion, i.e., $f^*(\cdot)$ is a scalar.⁸ Suppose the input domain of load as the multi-dimensional unit hyper-cube, i.e., $\mathbf{D} \in$ $[0,1]^{2^* \operatorname{card}(\mathcal{N})}$. We derive the following result by extending the analysis in [47] to the AC-OPF setting.

Theorem 4. Let **D** follow any continuous density function $p_{\mathbf{D}}$ over $[0,1]^{2 \cdot card(\mathcal{N})}$ that is lower-bounded by a positive constant. Let $\mathcal{K}_{m,L}$ be the class of all $f(\cdot)$ generated by a DNN with L hidden layers and at most m neurons per layer, and adopting

⁸To extend the results for mapping with one-dimensional output to the mapping with multi-dimensional outputs, one can apply the results for onedimensional output multiple times and combine them to get the desired result.

TABLE III: Parameters settings.

#Bus	#P-V Bus	#P-Q bus	#Branch	#Hidden layers	#Neurons per layer
30	5	24	41	2	64/32
118	53	63	231	2	256/128
300	68	231	411	2	512/256
2000	177	1822	3693	2	2048/1024

ReLU as the activation function. Let $f^*(\cdot)$ be the unique loadsolution mapping of an AC-OPF problem. If the absolute value of its Hessian's eigenvalues is lower bounded by a positive constant in a connected subset of the input domain whose measure is lower bounded by a positive constant, we have:

$$\min_{f \in \mathcal{K}_{m,L}} E_{\mathbf{D} \sim u_{\mathbf{D}}} \left[\left(f^* \left(\mathbf{D} \right) - f \left(\mathbf{D} \right) \right)^2 \right] \ge \frac{c}{\left(2m\right)^{4L}}, \quad (18)$$

where the constant c depends on the minimum of the density function and the minimum absolute value of the Hessian's eigenvalues.

Note that for AC-OPF problems, the Hessians of $f^{*}(\cdot)$ are usually not zero.⁹ Thus it is not difficult for the "bounded over a subset" assumption on Hessian's eigenvalues to hold in practice, which essentially requires $f^*(\cdot)$ to have some "curvature" for the nonlinear AC-OPF problem. Theorem 4 implies an order-wise lower bound when applying DNN to approximate a load-to-solution mapping of any AC-OPF problem. The bound decreases exponentially in L but polynomially in m. This highlights the benefits of using "deep" architecture in approximating the load-to-solution mapping of AC-OPF problems, similar to the observation for general functions in [47], [48]. For mapping over general input domain with different ranges for individual loads, one can first scale up/down the loads to adjust their ranges to [0, 1] and then apply the lower bound result in the above theorem. The order-wise lower bound of approximation error in (18) can be applied to uniform distribution (same as that in [47]) and truncated normal distribution. For example, the constant involved in the right-hand-side of (18) is one for the case of uniform distribution. These results provide theoretical justification of using DNN to solve AC-OPF problem.

VI. NUMERICAL EXPERIMENTS

A. Experiment Setup

We evaluate the performance of DeepOPF over the IEEE 30-/118-/300-bus [49] test cases and a synthetic 2000-bus mesh power network [50] in the Power Grid Lib [51]. Table III shows the related parameters for the test cases. As the Power Grid Lib only supports linear cost function for the IEEE 30-/118-/300-bus cases, we modify the cost parameters by applying the quadratic function parameters of the test cases from MATPOWER [52] (ver. 7.0) while all other parameters remain unchanged.

We generate two datasets used for each test case in the simulation. The first dataset corresponds to the scenario where

each load changes independently. In particular, the load data is sampled within [90%, 110%] of the default load uniformly at random. Note that, theoretically, the DNN approach can be applied to learn the load-to-solution mapping of any load sampling range. The second dataset corresponds to the scenario in which loads at buses are correlated (e.g., the peak loads at most buses appear simultaneously). Specifically, similar to [6], we generate the load data at each bus by multiplying the default value by an interpolated demand curve based on Californias daily net load from Dec. 1st to Dec. 8th, 2021, with a time granularity of 30 seconds. The generated real-time load data contains various correlated load demand variation up to 40%. We then use the AC-OPF solutions obtained by Pypower [33] as ground-truth. Finally, we generate uniformly-sampled and real-world datasets with 12,500 samples and use an 80%/20% split for training/test for each case.¹⁰

We design the DNN model based on the Pytorch platform and integrate the zero-order optimization technique with the widely-used Adam [53] algorithm for training. The training epoch and the batch size for all test cases are 200 and 32, respectively. We set the weighting factors in the loss function in (15) to be $w_1 = 1, w_2 = 0.1$ based on empirical experience. Table III also shows other related parameters of the DNN model, e.g., the number of hidden layers and the number of neurons in each layer.¹¹

We conduct simulations in CentOS 7.6 with quad-core (i7-3770@3.40G Hz) CPU and 16GB RAM. In addition to the state-of-the-art iterative solver (Pypower), we compare DeepOPF with the following DNN schemes:

- DNN-E: A method adapted from the one used in [14]. It trains a DNN to learn the load-solution mapping for solving AC-OPF problems without the penalty approach.
- DNN-W: A method adapted from the one used in [26]. It trains a DNN to predict the primal variables as the warm-start points to the conventional solver.

For a fair comparison, the training/testing samples are all set the same as DeepOPF, and the feasibility-recovery procedure is applied in case of in-feasibility. The evaluation metrics are the following (averaged over 2,500 test instances): (i) Feasibility rate: The percentage of the obtained feasible solution before feasibility-recovery procedure. A solution is regarded feasible only if it satisfies all AC-OPF constraints.¹² (ii) Cost: The corresponding power generation cost difference as compared to the Pypower. (iii) Speedup: The average running-time ratios of the Pypower to that of the DNN schemes taking the feasibility-recovery procedure are computed as speedup. Note that the speedup is the average of ratios, and it is different from

 12 In [14], [15], the feasibility is evaluated by the constraint violation rate average over all test instances. This, however, does not measure the fraction of the instances with all constraints satisfied, which is our feasibility definition.

⁹The Hessians can be zeros almost everywhere for the piece-wise DC-OPF load-to-solution mapping [8].

¹⁰In our study, we adopt a common practice in recent works, e.g., [15], [31], to select the size of training set and test set. From our simulation results, this amount of data is sufficient to obtain strong performance for the case studies. We leave the problem of determining the minimum number of samples needed to train the DNN with strong performance as a future direction.

¹¹We note that Theorem 4 in Sec. V shows the benefits of increasing the size of DNN in mapping approximation. However, the over-fitting issue may appear in practice for larger DNNs, resulting in performance degeneration. We follow a common practice to determine the DNN structure and size by educated guesses and iterative tuning for different test cases.

Test case	Fe before	asibility rate feasibility-r	ility rate (%) sibility-recovery*		Average cost difference (%)			Average speedup		
	DNN-E [†]	DNN-W	DeepOPF	DNN-E	DNN-W	DeepOPF	DNN-E	DNN-W	DeepOPF	
IEEE Case30	42	100	100	< 0.1	0	< 0.1	×12	×1.1	×24	
IEEE Case118	22	100	100	< 0.1	0	< 0.1	×4.2	×1.3	×22	
IEEE Case300	21	100	99	< 0.1	0	< 0.1	×5.4	×1.8	×20	
IEEE Case2000	29	100	99	< 0.1	0	< 0.1	×24	×1.0	×123	

TABLE IV: Performance comparisons for IEEE standard cases with uniformly-sampled load data ($\pm 10\%$ variation).

* Feasibility rates after feasibility-recovery are 100% for DNN-E and DeepOPF.

[†] After obtaining the solution variables, DNN-E as in [14] projects the infeasible ones (e.g., reactive power generation at P-V buses) onto the corresponding box constraints and re-solves the AC-PF equations one more time for the remaining variables. We note that such a post-processing process does not guarantee the final solutions respect the branch-flow limits, thus the low feasibility rates.

TABLE V: Performance comparisons for IEEE standard cases with real-world load profiles with up to 40% demand variation.

Test case	Feasibility rate (%) before feasibility-recovery*			Average cost difference (%)			Average speedup		
	DNN-E	DNN-W	DeepOPF	DNN-E	DNN-W	DeepOPF	DNN-E	DNN-W	DeepOPF
IEEE Case30	36	100	100	< 0.1	0	< 0.1	$\times 7.3$	$\times 1.0$	$\times 13$
IEEE Case118	80	100	99	< 0.1	0	< 0.1	×11	$\times 1.1$	$\times 12$
IEEE Case300	49	100	100	< 0.2	0	< 0.2	$\times 16$	$\times 1.7$	$\times 33$
IEEE Case2000	60	100	100	< 0.2	0	< 0.2	$\times 44$	$\times 0.9$	$\times 70$

* Feasibility rates after feasibility-recovery are 100% for DNN-E and DeepOPF.

the ratio of the average running times between the Pypower and DNN schemes.

B. Performance Evaluation under Test Datasets

We show the simulation results of the proposed approach for the test cases with the synthetic and real-world load profiles in Tables IV and V. We have the following observations. First, substantial improvements in the feasibility can be achieved when applying the penalty approach. The feasibility rate increases up to 80% as compared to DNN-E.¹³ Overall, DeepOPF obtains > 99% feasibility rate before the feasibility-recovery procedure, demonstrating the usefulness of the penalty approach. Second, DeepOPF achieves an average optimality loss of less than 0.2% and a speedup performance of ×123 (two orders of magnitude), as compared to conventional AC-OPF solver on two datasets. It demonstrates the effectiveness of DeepOPF in dealing with both small-/large-variation load profiles. We also compare the DNNpredict solution with the ground-truths for IEEE Case118 for a specific test instance in Fig. 2. The results show that DeepOPF can achieve desirable prediction results and thus suggest minor optimality loss. In addition, DeepOPF achieves decent speedup performance, which has included time used by the feasibility-recovery procedure. The speedup performance also demonstrates the scalability of the proposed approach and its potential for solving larger-scale AC-OPF problems. Third, as compared to the hybrid scheme (DNN-W) using DNN to predict the warm-start points, DeepOPF achieves noticeably better speedup performance and similar feasibility and optimality performance. These results demonstrates effectiveness of employing DNNs to solve AC-OPF problems directly.

C. Performance with Different Penalty Weighting Factors

We also evaluate the performance of DeepOPF with different weighting factors in the loss function for training. Specifically, we use IEEE Case118 with synthetic load profiles and choose two variants of the weighting factors as follows:

- Weights-V1: $w_1 = 1$ and $w_2 = 1$.
- Weights-V2: $w_1 = 1$ and $w_2 = 0.1$.

They assign different priorities in the prediction error and the penalty term to pursue optimality and preserve feasibility. We compare two variants' results in terms of feasibility rate, speedup, and the average optimality gap to the conventional solver on the test data set. As seen in Table VI, although adding penalty improves the speedup of the approach as it involves less in-feasible instances, a larger value of w_2 may cause a higher optimality difference as the DNN model pays more attention to reduce the penalty during the training, affecting prediction performance and the final optimality difference. In practice, one can start with an initial value and then tune the value towards satisfactory training performance. We leave setting weighting factors systematic as a future direction.

D. Performance with Different Gradient Computation Methods

We carry out experiments under the same setting to compare the optimality loss and feasibility of two DeepOPF variants on IEEE case30 and case118 test cases with the synthetic load profiles:

- DeepOPF-ZO: the DeepOPF with zero-order technique for estimating the penalty gradient.
- DeepOPF-IF: the DeepOPF scheme by utilizing implicit function theorem, to compute the penalty gradient. We noted that this is the method adapted from the one used in [17]. The idea is to first compute the partial derivatives of power flows w.r.t x_{pred} and x_{rec} and then obtain the gradient of x_{rec} w.r.t x_{pred} and the $\nabla \mathcal{L}_{pen}(s_{pred})$ by using the chain rule.

¹³Note that in DNN-E, the power-flow equality constraints are always satisfied. But the reactive power and line limit constraints may be violated as they are not considered during the DNN training.



Fig. 2: Comparisons of the DeepOPF solutions and the Pypower solutions for the IEEE Case118 test case. There are 53 P-V buses in total, and 18 of them are associated with active power generation. (a) The differences on active power generations on the 18 PV buses with active power generation. (b) The differences on voltage magnitudes at the first 26 P-V buses.

TABLE VI: Performance comparisons of weighting-factor variants.

Weight setting	Feasibility rate (%) before feasibility-recovery	Cost diff. (%)	Avg. speedup
Weights-V1	100	1.5	× 22
Weights-V2	100	< 0.1	× 22

The results are shown in Table. VII. Interestingly, we observe in the simulations that DeepOPF-ZO achieves the same performance as DeepOPF-IF, except for a better feasibility rate. This indicates that DeepOPF-ZO is able to train a DNN with similar, sometimes better, performance than DeepOPF-IF. The explanation for this observation may be that the estimated gradient (with noise) could help the DNN model to escape the bad local minimum during the training process and achieve better performance. Similar observations are also reported in [54] for training DNN in other problem domains.

In general, both schemes have their own merits. DeepOPF-IF can compute the exact gradient to guide the training, given a well-characterized and computationally efficient model. In practice, however, such a model may be difficult to obtain due to sophisticated equipment operation mechanisms in the power system. For example, for the AC-OPF problem with wind turbine controls for increasing power capture, it is difficult to model the relationship between the control variable and wind-turbine output due to the complex control mechanism [55]. In practice, the wind farm's output evaluation proceeds through simulation/measurement apparatus, and no mathematical model exists for computing penalty gradients directly. For such problems, it may be more convenient to use DeepOPF-ZO instead of DeepOPF-IF.

VII. CONCLUSION AND FUTURE DIRECTIONS

We develop a feasibility-optimized DNN for solving AC-OPF problems. To ensure that the power-flow balance constraints are satisfied, DeepOPF first predicts a set of independent variables and then reconstructs the remaining variables by solving the AC power flow equations. We also adopt a penalty approach in the DNN training to respect the inequality constraints. We further apply a zero-order optimization-based

TABLE VII: Performance comparison of DeepOPF variants.

Test case	Variants	Feasibility rate (%) before feasibility-recovery	Cost diff(%)	Avg. speedup
Case-30	DeepOPF-ZO	100	< 0.1	×24
	DeepOPF-IF	100	< 0.1	×24
Case-118	DeepOPF-ZO	100	< 0.1	×22
	DeepOPF-IF	95	< 0.1	×21

training algorithm to compute the penalty gradient efficiently. Simulation results on IEEE 30/118/300-bus and a synthetic 2000-bus test cases show the effectiveness of the penalty approach and that DeepOPF speeds up the computing time by two-orders of magnitude as compared to conventional optimization-based solvers with minor cost difference. Empirical results also reveal the advantage of zero-order technique on training DNN model to achieve better performance. DeepOPF develops one DNN model for solving AC-OPF problems with varying load inputs but fixed power network topology and parameters (e.g., line impedance) and other physical/operational constraints. Thus, upon contingencies, e.g., line outage and transmission switching, one may need to load a pre-trained DNN model to solve AC-OPF problems with revised topology, line parameters, or constraints. It is of great interest to explore DNN designs that are robust to changes in system topologies or parameters. Another interesting future directions is to extend DeepOPF to AC-OPF problems with multiple load-solution mappings [56].

ACKNOWLEDGEMENT

We thank Titing Cui, Wanjun Huang, Qiulin Lin, and Andreas Venzke for the discussions related to this study. We would like to thank Ying Guo and the National Supercomputer Center in Jinan for providing GPU/CPU computing resources. We would also like to thank the anonymous reviewers for careful reading and the helpful comments.

REFERENCES

J. Carpentier, "Contribution to the Economic Dispatch Problem," Bulletin de la Societe Francoise des Electriciens, vol. 3, no. 8, pp. 431–447, 1962.

- [2] M. B. Cain, R. P. Oneill, and A. Castillo, "History of Optimal Power Flow and Formulations," *Federal Energy Regulatory Commission*, vol. 1, pp. 1–36, 2012.
- [3] Y. Zhang, E. Dall'Anese, and M. Hong, "Dynamic ADMM for Real-Time Optimal Power Flow," in *Proc. IEEE GlobalSIP*, Nov. 2017, pp. 1085–1089.
- [4] L. Zhang, Y. Chen, and B. Zhang, "A Convex Neural Network Solver for DCOPF with Generalization Guarantees," *IEEE Trans. Control Netw. Syst., to be published*, 2021.
- [5] S. Babaeinejadsarookolaee, A. Birchfield, R. D. Christie, C. Coffrin, C. DeMarco, R. Diao, M. Ferris, S. Fliscounakis, S. Greene, R. Huang *et al.*, "The Power Grid Library for Benchmarking AC Optimal Power Flow Algorithms," *arXiv preprint arXiv:1908.02788*, 2019.
- [6] Y. Tang, K. Dvijotham, and S. Low, "Real-Time Optimal Power Flow," IEEE Trans. Smart Grid, vol. 8, no. 6, pp. 2963–2973, Nov. 2017.
- [7] X. Pan, T. Zhao, and M. Chen, "DeepOPF: Deep Neural Network for DC Optimal Power Flow," in *Proc. IEEE SmartGridComm*, Oct. 2019, pp. 1–6.
- [8] X. Pan, T. Zhao, M. Chen, and S. Zhang, "DeepOPF: A Deep Neural Network Approach for Security-Constrained DC Optimal Power Flow," *IEEE Trans. Power Syst.*, vol. 36, no. 3, pp. 1725–1735, May 2021.
- [9] T. Zhao, X. Pan, M. Chen, A. Venzke, and S. H. Low, "DeepOPF+: A Deep Neural Network Approach for DC Optimal Power Flow for Ensuring Feasibility," in *Proc. IEEE SmartGridComm*, Nov. 2020, pp. 1–6.
- [10] K. Hornik, "Approximation Capabilities of Multilayer Feedforward Networks," *Neural Networks*, vol. 4, no. 2, pp. 251–257, 1991.
- [11] A. Velloso and P. Van Hentenryck, "Combining Deep Learning and Optimization for Preventive Security-Constrained DC Optimal Power Flow," *IEEE Trans. Power Syst.*, vol. 36, no. 4, pp. 3618–3628, 2021.
- [12] D. Owerko, F. Gama, and A. Ribeiro, "Optimal Power Flow using Graph Neural Networks," in *Proc. IEEE ICASSP*, May 2020, pp. 5930–5934.
- [13] N. Guha, Z. Wang, M. Wytock, and A. Majumdar, "Machine Learning for AC Optimal Power Flow," in *Proc. ICML Workshop*, Jun. 2019.
- [14] A. Zamzam and K. Baker, "Learning Optimal Solutions for Extremely Fast AC Optimal Power Flow," in *Proc. IEEE SmartGridComm*, Nov. 2020.
- [15] M. Chatzos, F. Fioretto, T. W. Mak, and P. Van Hentenryck, "High-Fidelity Machine Learning Approximations of Large-Scale Optimal Power Flow," *arXiv preprint arXiv:2006.16356*, 2020.
- [16] R. Dobbe, O. Sondermeijer, D. Fridovich-Keil, D. Arnold, D. Callaway, and C. Tomlin, "Towards Distributed Energy Services: Decentralizing Optimal Power Flow with Machine Learning," *IEEE Trans. Smart Grid*, vol. 11, pp. 1296–1306, Nov. 2019.
- [17] P. L. Donti, D. Rolnick, and J. Z. Kolter, "DC3: A Learning Method for Optimization with Hard Constraints," in *Proc. ICLR*, Apr. 2021.
- [18] D. Deka and S. Misra, "Learning for DC-OPF: Classifying Active Sets using Neural Nets," in *Proc. IEEE Milan PowerTech*, Jun. 2019, pp. 1–6.
- [19] Y. Ng, S. Misra, L. A. Roald, and S. Backhaus, "Statistical Learning for DC Optimal Power Flow," in *Proc. PSCC*, 2018, pp. 1–7.
- [20] Y. Chen and B. Zhang, "Learning to Solve Network Flow Problems via Neural Decoding," arXiv preprint arXiv:2002.04091, 2020.
- [21] S. Pineda, J. M. Morales, and A. Jimnez-Cordero, "Data-driven screening of network constraints for unit commitment," *IEEE Trans. Power Syst.*, vol. 35, no. 5, pp. 3695–3705, Mar. 2020.
- [22] A. Robson, M. Jamei, C. Ududec, and L. Mones, "Learning an Optimally Reduced Formulation of OPF through Meta-Optimization," arXiv preprint arXiv:1911.06784, 2019.
- [23] D. Biagioni, P. Graf, X. Zhang, A. S. Zamzam, K. Baker, and J. King, "Learning-Accelerated ADMM for Distributed DC Optimal Power Flow," *IEEE Control Syst. Lett.*, vol. 6, pp. 1–6, Dec. 2022.
- [24] K. Baker, "Learning warm-start points for ac optimal power flow," in *Proc. IEEE MLSP.* IEEE, 2019, pp. 1–6.
- [25] F. Diehl, "Warm-Starting AC Optimal Power Flow with Graph Neural Networks," in *Proc. NeurIPS Workshop*, Dec. 2019.
- [26] W. Dong, Z. Xie, G. Kestor, and D. Li, "Smart-PGSim: Using Neural Network to Accelerate AC-OPF Power Grid Simulation," in *Proc. SC20*, 2020, pp. 1–15.
- [27] K. Baker, "A Learning-boosted Quasi-Newton Method for AC Optimal Power Flow," arXiv preprint arXiv:2007.06074, 2020.
- [28] L. Zhang and B. Zhang, "Learning to Solve the AC Optimal Power Flow via a Lagrangian Approach," arXiv preprint arXiv:2110.01653, 2021.
- [29] T. Zhao, X. Pan, M. Chen, and S. H. Low, "Ensuring DNN Solution Feasibility for Optimization Problems with Convex Constraints and Its Application to DC Optimal Power Flow Problems," *arXiv preprint* arXiv:2112.08091, 2021.

- [30] X. Lei, Z. Yang, J. Yu, J. Zhao, Q. Gao, and H. Yu, "Data-Driven Optimal Power Flow: A Physics-Informed Machine Learning Approach," *IEEE Trans. Power Syst.*, vol. 36, no. 1, pp. 346–354, Jan. 2021.
- [31] M. K. Singh, V. Kekatos, and G. B. Giannakis, "Learning to Solve the AC-OPF using Sensitivity-Informed Deep Neural Networks," *IEEE Trans. Power Syst.*, vol. 37, no. 4, pp. 2833–2846, Jul. 2022.
- [32] F. Fioretto, T. W. Mak, and P. Van Hentenryck, "Predicting AC Optimal Power Flows: Combining Deep Learning and Lagrangian Dual Methods," in *Proc. AAAI*, Feb. 2020, pp. 630–637.
- [33] "Pypower," 2018, https://pypi.org/project/PYPOWER/.
- [34] X. Pan, M. Chen, T. Zhao, and S. H. Low, "DeepOPF: A Feasibility-Optimized Deep Neural Network Approach for AC Optimal Power Flow Problems," arXiv preprint arXiv:2007.01002, 2020.
- [35] W. Huang and M. Chen, "DeepOPF-NGT: A Fast Unsupervised Learning Approach for Solving AC-OPF Problems without Ground Truth," in *Proc. ICML Workshop*, Jul. 2021.
- [36] Y. Zhou, B. Zhang, C. Xu, T. Lan, R. Diao, D. Shi, Z. Wang, and W.-J. Lee, "Deriving Fast AC OPF Solutions via Proximal Policy Optimization for Secure and Economic Grid Operation," *arXiv preprint arXiv:2003.12584*, 2020.
- [37] W. Huang, X. Pan, M. Chen, and S. H. Low, "DeepOPF-V: Solving AC-OPF Problems Efficiently," *IEEE Trans. Power Syst.*, vol. 37, no. 1, pp. 800–803, Sept. 2022.
- [38] B. Subhonmesh, S. H. Low, and K. M. Chandy, "Equivalence of Branch Flow and Bus Injection Models," in *Proc. ALLERTON*, Oct. 2012, pp. 1893–1899.
- [39] D. Bienstock and A. Verma, "Strong NP-hardness of AC power flows feasibility," Oper. Res. Lett., vol. 47, no. 6, pp. 494–501, Nov. 2019.
- [40] S. H. Low, "Convex Relaxation of Optimal Power FlowPart II: Exactness," *IEEE Trans. Control. Netw. Syst.*, vol. 1, no. 2, pp. 177–189, May 2014.
- [41] I. Goodfellow, Y. Bengio, A. Courville, and Y. Bengio, *Deep Learning*. MIT Press Cambridge, 2016, vol. 1.
- [42] D. Mehta, D. K. Molzahn, and K. Turitsyn, "Recent Advances in Computational Methods for the Power Flow Equations," in *Proc. ACC*, Jul. 2016, pp. 1753–1765.
- [43] A. Agarwal, O. Dekel, and L. Xiao, "Optimal Algorithms for Online Convex Optimization with Multi-Point Bandit Feedback," in *Proc. COLT*. Omnipress, Jul. 2010, pp. 28–40.
- [44] S. Liu, P. Y. Chen, B. Kailkhura, G. Zhang, A. O. Hero III, and P. K. Varshney, "A Primer on Zeroth-Order Optimization in Signal Processing and Machine Learning: Principals, Recent Advances, and Applications," *IEEE Signal Process. Mag.*, vol. 37, no. 5, pp. 43–54, Sept. 2020.
- [45] S. Ghadimi and G. Lan, "Stochastic First-and Zeroth-order Methods for Nonconvex Stochastic Programming," *SIAM Journal on Optimization*, vol. 23, no. 4, pp. 2341–2368, Dec. 2013.
- [46] K. Hornik, "Approximation Capabilities of Multilayer Feedforward Networks," *Neural Networks*, vol. 4, no. 2, pp. 251 – 257, 1991.
- [47] I. Safran and O. Shamir, "Depth-Width Tradeoffs in Approximating Natural Functions with Neural Networks," in *Proc. ICML*, vol. 70, Aug. 2017, pp. 2979–2987.
- [48] S. Liang and R. Srikant, "Why Deep Neural Networks for Function Approximation?" in *Proc. ICLR*, Apr. 2017.
- [49] "Power Systems Test Case Archive," 2018, http://labs.ece.uw.edu/pstca/.
 [50] "2000-bus Synthetic Test Case," 2022, https://electricgrids.engr.tamu.
- edu/electric-grid-test-cases/activsg2000/.
- [51] I. Power and E. Society, "Power grid lib-v19.05," https://github.com/ power-grid-lib/pglib-opf.
- [52] R. D. Zimmerman, C. E. Murillo-Sánchez, R. J. Thomas *et al.*, "MAT-POWER: Steady-state operations, planning, and analysis tools for power systems research and education," *IEEE Trans. Power Syst.*, vol. 26, no. 1, pp. 12–19, Feb. 2011.
- [53] D. P. Kingma and J. Ba, "Adam: A Method for Stochastic Optimization," in *Proc. ICLR*, May 2015.
- [54] A. Neelakantan, L. Vilnis, Q. V. Le, I. Sutskever, L. Kaiser, K. Kurach, and J. Martens, "Adding Gradient Noise Improves Learning for Very Deep Networks," in *Proc. ICLR*, May 2016.
- [55] J. R. Marden, S. D. Ruben, and L. Y. Pao, "A Model-Free Approach to Wind Farm Control using Game Theoretic Methods," *IEEE Trans. Control Syst. Technol.*, vol. 21, no. 4, pp. 1207–1214, May 2013.
- [56] X. Pan, W. Huang, M. Chen, and S. H. Low, "DeepOPF-AL: Augmented Learning for Solving AC-OPF Problems with Multiple Load-Solution Mappings," arXiv preprint arXiv:2206.03365, 2022.



Xiang Pan (S'18) received his B.Eng. in computer science from Shandong University, Jinan, China, in 2015, and M.S. degree in computer science from Wuhan University, Wuhan, China, in 2018. He is currently pursuing his Ph.D. degree in the Department of Information Engineering, The Chinese University of Hong Kong, Hong Kong. His recent research interests include machine learning for networked systems (e.g., power systems) and signal processing (e.g., image/video coding).



Minghua Chen (S'04-M'06-SM'13-F'22) received his B.Eng. and M.S. degrees from the Department of Electronic Engineering at Tsinghua University. He received his Ph.D. degree from the Department of Electrical Engineering and Computer Sciences at University of California Berkeley. He is currently a Professor of School of Data Science, City University of Hong Kong. Minghua received the Eli Jury award from UC Berkeley in 2007 (presented to a graduate student or recent alumnus for outstanding achievement in the area of Systems, Communica-

tions, Control, or Signal Processing) and The Chinese University of Hong Kong Young Researcher Award in 2013. He also received IEEE ICME Best Paper Award in 2009, IEEE Transactions on Multimedia Prize Paper Award in 2009, ACM Multimedia Best Paper Award in 2012, and IEEE INFOCOM Best Poster Award in 2021. He receives the ACM Recognition of Service Award in 2017 and 2020 for the service contribution to the research community. He is currently a Senior Editor for IEEE Systems Journal, an Area Editor of ACM SIGEnergy Energy Informatics Review, and an Award Chair of ACM SIGEnergy. Minghua's recent research interests include online optimization and algorithms, machine learning in power systems, intelligent transportation systems, distributed optimization, and delay-critical networked systems. He is an ACM Distinguished Scientist and an IEEE Fellow.



Tianyu Zhao is a staff researcher in Lenovo Machine Intelligence Center, Lenovo, Hong Kong. Before joining Lenovo, he worked as a postdoctoral researcher supervised by Professor Minghua Chen at City University of Hong Kong, Hong Kong. Dr. Zhao received his Ph.D. degree from the Department of Information Engineering, The Chinese University of Hong Kong, Hong Kong, in January 2022. He received the B.Eng. degree from the School of Energy and Power Engineering and the Minor's Diploma in Business Administration from the School of Man-

agement, Xi'an Jiaotong University, Xi'an, China, in 2017. His research interests include electricity market, microgrid operation, and machine learning applications in power systems and network optimizations.



Steven Low is the F. J. Gilloon Professor of the Department of Computing & Mathematical Sciences and the Department of Electrical Engineering at Caltech. Before that, he was with AT&T Bell Laboratories, Murray Hill, NJ, and the University of Melbourne, Australia. He was a co-recipient of IEEE best paper awards, an awardee of the IEEE INFOCOM Achievement Award and the ACM SIG-METRICS Test of Time Award, and is a Fellow of IEEE, ACM, and CSEE. He was well-known for work on Internet congestion control and semidefinite

relaxation of optimal power flow problems in smart grid. His research on networks has been accelerating more than 1TB of Internet traffic every second since 2014. His research on smart grid is providing large-scale cost effective electric vehicle charging to workplaces. He received his B.S. from Cornell and PhD from Berkeley, both in EE.